
Underfloor Heating Programmable Thermostat




t: 01923 249026 m: 07941 169635 w: www.gs-ufh.co.uk e: gs@warmfloors.co.uk



TO CHANGE THE TIMINGS

- AT ANY STAGE DURING THE PROCESS YOU CAN PRESS "A" TO SAVE CHANGES AND EXIT.
- PRESS THE "CLOCK" BUTTON ONCE, THE TIME WILL FLASH.
- PRESS UP AND DOWN TO ADJUST "WAKE" TIME. WHEN HAPPY PRESS "H".
- SELECT THE DESIRED TEMPERATURE FOR THE PERIOD BY PRESSING UP AND DOWN. WHEN HAPPY PRESS "H".
- SELECT THE "LEAVE" TIME FOR THE PERIOD BY PRESSING UP AND DOWN. WHEN HAPPY PRESS "H".
- SELECT THE DESIRED OFF TEMPERATURE BY PRESSING UP AND DOWN. WHEN HAPPY PRESS "H".
- IF YOU WANT TO SET "RETURN" AND "SLEEP" TIMES DO THE SAME PROCESS ABOVE, IF NOT PRESS "H" UNTIL YOU COME TO SETTINGS FOR SATURDAY AND SUNDAY AND DO THE SAME AGAIN.
- IF THE TIMER IS ON BUT YOU WANT TO INCREASE OR DECREASE THE TEMPERATURE FOR THE DAY PRESS UP OR DOWN TO CHANGE THE DESIRED TEMPERATURE.



LCD Display

- Galliard
- Room/Floor Temp Indicates the current temperature sensor mode.
- Day Indicator Displays the current day.
- Frost Icon Displayed when the thermostat is in frost protection mode.
 Flame Icon Displayed when the thermostat is calling for heat, the flame icon
- will flash when the optimum start function is in operation.
 Floor Temp Limit Icon Displayed when the floor sensor probe has reached the temperature limit set on feature 09.
- Temperature Hold When a Temp Hold is active, HOLD FOR and the remaining time period is displayed.
- Set Indicates when changes are being made to programs or temperature set
- Holiday Indicator Displayed when the thermostat is in holiday mode.
- Current Temp Indicates the current sensor temperature.

 Program Cycle Indicator Displayed during programming only to show which period is being altered.
- Keypad Lock Indicator Displayed when the keypad is locked. Units of Temperature Degrees Celsius or Fahrenheit. 11.
- Clock Digital clock display in 24h format.




To set the clock, follow these steps.

- With the thermostat turned ON, press the Clock key twice Use the Up/Down keys to set the hours Н Press H to confirm settings Н Press H to confirm settings
 - Day 15:08 Minutes SET

Temperature Display

This thermostat can be setup to use an air sensor, floor sensor or both.

The display will clearly show which sensor is being controlled by showing either:



Note: Built in air sensor only MUST NOT be used to control electric underfloor heating. Floor sensor only or built in air & floor sensor together must be used

When the thermostat is set to use both sensors, the room temperature will be displayed. To view the floor temperature, press and hold the A key until the Floor Temp is displayed on screen.

Model: PRT-EN

Comfort Levels Explained


The thermostat provides Weekday/Weekend or 7 Day Programming options. You should consult the "Optional Features" section to select the required mode.

The thermostat is supplied with comfort levels already programmed, but these can be changed easily. The default times and temperatures are;

08.00 - 21°C (Wake) 09.30 - 16°C (Leave) 16.30 - 22°C (Return) 23.00 - 17°C (Sleep)

If you only want to use 2 levels, you should program the unused levels to -----Note: For Weekday/Weekend programming, the 4 comfort levels are the same for all weekdays but can be different for the weekends.

For 7 Day programming, each day can have 4 different comfort levels.



For 7 Day programming, only Mon is displayed in the day indicator field.

- Use the Up/Down keys to enter the required WAKE time Н Press H to confirm settings lackUse the Up/Down keys to enter the required WAKE temperature Press H to confirm settings
- You will now see "LEAVE" displayed on screen.
 - Repeat the programming steps for each period until complete.
- For unused periods enter --.-- and the thermostat will ignore the setting.
- Press A to confirm settings and return to main display
- In 7 Day programming mode you can repeat for each day independently.
- In Weekday/Weekend programming mode you will see Sat Sun displayed on screen and can repeat for the weekend.
- To change the programming mode please refer to pages 21-22.

Model: PRT-EN




Locking the Thermostat

For Weekday/Weekend programming, Mon Tue Wed Thu Fri are displayed on screen.

The thermostat has a keypad lock facility. To activate the lock follow these steps.

- You will see the lock symbol appear on screen
- To unlock, repeat the steps above until the lock symbol disappears.

Note: The keypad lock indicator is only displayed when the lock is active.



Temperature Control

When you press either key, you will see the word SET and the desired temperature will be displayed on screen. Use the Up/Down keys to adjust the SET value Press A to confirm settings and return to main display Note: This override will be maintained until the next programmed comfort level.

Set Temperature Set Icon

Model: PRT-EN

heatmiser







Model: PRT-EN





3-4 5-6 7-8 Setting the Clock Temperature Display 10 Setting the Comfort Levels 11-12 Locking the Thermostat 13 Setting the Temperature 14 Temperature Hold 15 Holiday Programming 16 Frost Protection 17 Power On / Off Optional Features 19-22 Re-calibrating the Thermostat 23 Factory Reset 24 Wiring Diagrams 25-26

Slimline Series Model: PRT-EN

?

What is a Programmable Room Thermostat?

A programmable room thermostat is both a programmer and a room thermostat.

A programmer allows you to set "On" and "Off" periods to suit your own lifestyle. A room thermostat works by sensing the air temperature, switching on the heating when the air temperature falls below the thermostat setting, and switching it off once this set temperature has been reached.

So a programmable room thermostat lets you choose what times you want the heating to be on, and what temperature it should reach while it is on. It will allow you to select different temperatures in your home at different times of the day (and days of the week) to meet your particular needs and preferences.

Setting a programmable room thermostat to a higher temperature will not make the room heat up any faster. How quickly the room heats up depends on the design and size of the heating system.

Similarly reducing the temperature setting does not affect how quickly the room cools down. Setting a programmable room thermostat to a lower temperature will result in the room being controlled at a lower temperature, and saves energy.

The way to set and use your programmable room thermostat is to find the lowest temperature settings that you are comfortable with at the different times you have chosen, and then leave it alone to do its job.

The best way to do this is to set the room thermostat to a low temperature - say 18°C, and then turn it up by 1°C each day until you are comfortable with the temperature. You won't have to adjust the thermostat further. Any adjustment above this setting will waste energy and cost you more money.

You are able to temporarily adjust the heating program by overriding or using the temperature hold feature. These features are explained further on pages 14 and 15 of this manual.

Programmable room thermostats need a free flow of air to sense the temperature, so they must not be covered by curtains or blocked by furniture. Nearby electric fires, televisions, wall or table lamps may also prevent the thermostat from working properly.

Slimline Series

Model: PRT-EN



Installation Procedure



Do

Mount the thermostat at eye level. Read the instructions fully so you get the best from our product.



Don't

Do not install near to a direct heat source as this will affect functionality. Do not push hard on the LCD screen as this may cause irreparable damage.

This Slimline Series thermostat is designed to be flush mounted and requires a back box of 35mm (minimum depth) to be sunk into the wall prior to installation.

Step '

Carefully separate the front half of the thermostat from the back plate by placing a small flat head terminal driver into the slots on the bottom face of the thermostat.

Step 2

Place the thermostat front somewhere safe.

Terminate the thermostat as shown in the diagrams on page 25-26 of this booklet.

Step 3

Screw the thermostat back plate securely into the back box.

Step 4

 $\operatorname{\mathsf{Clip}}\nolimits$ the front of the thermostat back onto the thermostat back plate.









Slimline Series Model: PRT-EN




The temperature hold function allows you to manually override the current operating program and set a different temperature for a desired period.

5	
Press H to commence temperature hold	Н
Use the Up/Down keys to enter the required Hold time	▲ ▼
Press H to confirm settings	Н
Use the Up/Down keys to enter the required Hold temperature	▲ ▼
Press A to confirm settings and return to main display	Α

You will see the Hold For indication is displayed on screen.

The time will countdown the set duration and then revert to the normal program.



To cancel temperature hold, follow the same steps but reduce the Hold time to 00:00 hours.

Holiday

Galliare HEATING Galliare

The holiday function reduces the set temperature in your home to the frost protection temperature setting (see page 19).

The thermostat will maintain this temperature for the duration of the holiday and will then automatically return to the program schedule on your return.

- Press A to confirm settings and return to main display

 The display will show a suitcase indicating the thermostat is in holiday mode.

Note: A holiday period does not start until 00:00 the next day. For example, if you set a holiday period on Friday for 2 days, Saturday will be counted as the first day and the thermostat will revert back to the programmed schedule at 00:00 on Monday.




To cancel, follow the same steps but reduce the Holiday duration to 00 days.

5 Slimline Series Model: PRT-EN



Pressing the Power button once will place the thermostat in frost protect mode. In this mode, the thermostat will display the frost icon and will only turn the heating on should the room temperature drop below the set frost temperature (see page 19).

Should the heating be turned on whilst in frost mode, the flame icon will be displayed. To cancel the frost protect mode, press the Power button once again.





The heating is indicated ON when the flame icon is displayed.

When the flame icon is absent, there is no requirement for heating to achieve the set temperature but the thermostat remains active.

Thermostat completely OFF



OGHAVA

Thermostat powered ON

heatmiser

O G H A V A

*See Feature 3 on page 19

17 Slimline Series Model: PRT-EN



🦳 Optional Features Explained

THE FOLLOWING SETTINGS ARE OPTIONAL AND IN MOST CASES NEED NOT BE ADJUSTED

Feature 01 - Temperature Format: This function allows you to select between °C and °F.

Feature 02 - Switching Differential: This function allows you to increase the switching differential of the thermostat. The default is 1°C which means that with a set temperature of 20°C, the thermostat will switch the heating on at 19°C and off at 20°C. With a 2°C differential, the heating will switch on at 18°C and off at 20°C.

Feature 03 - Frost Protect: You can set whether the thermostat will maintain the frost temperature when the thermostat display is turned off. As a default, this is enabled.

Feature 04 - Frost Protect Temperature: This is the temperature maintained when the thermostat is in frost mode. The range is 07 - 17°C. The default is 12°C and is suitable for most a policy large.

Feature 05 – Output Delay: To prevent rapid switching, an output delay can be entered. This can be set from 00 - 15 minutes. The default is 00 which means there is no delay.

Feature 06 – Communication Address: This setting is used when you have connected your thermostat to a network system. Each thermostat on the network must have a unique communication address. This can be set from 01-32.

Feature 07 – Temperature Up/Down Limit: This function allows you to limit the use of the up and down keys. This limit is also applicable when the thermostat is locked and so allows you to give others limited control over the heating system.

Feature 08 – Sensor Selection: On this thermostat, you can select which sensor should be used. You can select between air temperature only, floor temperature, or both. When you enable both sensors, the floor sensor is used as a floor limiting sensor and is designed to prevent the floor from overheating.

Note: Built in air sensor only MIST NOT be used to control electric underfloor heating.

Note: Built in air sensor only MUST NOT be used to control electric underfloor heating.
Floor sensor only or built in air & floor sensor together must be used.

Feature 00 - Floor Term Limit: This function is available when mode 08 is set to

Feature 09 - Floor Temp Limit: This function is available when mode 08 is set to 02, 03 or 04. You can set a floor limiting temperature between 20-45°C (28°C is the default).

Feature 10 – Optimum Start: Optimum start will delay the start up of the heating system to the latest possible moment to avoid unnecessary heating and ensure the building is warm at the programmed time. The thermostat uses the rate of change information to calculate how long the heating needs to raise the building temperature 1°C (with a rate of change of 20, the thermostat has calculated the heating needs 20 minutes to raise the building temperature 1°C) and starts the heating accordingly.

On this thermostat, optimum start works on the Wake and Return comfort levels.

Feature 11 - Rate of Change: Number of minutes to raise the temperature by 1°C.


Feature 12 - Weekday/Weekend or 7 Day Programming: The thermostat offers two programming methods. Weekday/ Weekend allows you to program 4 comfort levels for the weekday and 4 different comfort levels for the weekend. In 7 Day program mode, each day has 4 comfort levels that can be programmed independently.

9 Slimline Series Model: PRT-EN 20



Adjusting the Optional Settings

To adjust the optional settings, follow these steps.



Use the Clock key to cycle through the features	Ф
Use the Up/Down keys to change the setting	•
Press A to confirm settings	Α
Press the Power button once again to turn the thermostat back ON	ወ

Optional Settings - Feature Table

FEATURE	DESCRIPTION	SETTING
01	Temperature Format	00 = °C, 01 = °F (°C = Default)
02	Switching Differential	01° - 03°C (01°C = Default)
03	Frost Mode	00 = Enabled, 01 = Disabled (00 = Default)
04	Frost Protection Temperature	07° - 17°C (12°C = Default)
05	Output Delay	00 - 15 Minutes (00 = Default)
06	Communications ID No.	Enter Comms number 01-32
07	Up/Down Temperature Limit	00° - 10°C (00 = Default)
08	Sensor Selection	00 = Built in Sensor
		01 = Remote Air Sensor
		02 = Floor Sensor Only
		03 = Built In & Floor Sensor
		04 = Remote Air & Floor Sensor
09	Floor Temperature Limit	20° - 45°C (28°C = Default)
10	Optimum Start	00 - 03 Hours (00 = Default)
11	Rate of Change	Minutes to raise by 1°C
12	Program Mode	00 = Weekday/Weekend 01 = 7 Day Programming

1 Slimline Series Model: PRT-EN 2








_ Ф Press and hold BOTH the Power and Down keys together until the Ф ▼ temperature appears on the screen ▲ ▼ • Use the Up/Down keys to configure the new temperature ... Α Press A to confirm settings

Press the Power button once to turn the thermostat back ON





The thermostat has a reset function to restore all settings to their factory defaults.


To perform a factory reset, follow these steps.

- Press and hold the Power button to turn the thermostat OFF
- Press and note the Fower and Up keys together until the LCD powers up.
- When the icons have disappeared from the screen, the thermostat has been successfully reset.




Factory reset is complete.

Wiring Diagram - PRT-EN to UH1



Wiring Diagram - PRC Voltfree Switching



Model: PRT-EN

.... ტ



Heating Professionals:

Request a copy of our product installation guide containing detailed technical specifications

Want More Information?

Or view technical specifications directly on our website: www.heatmiser.com







